



NOTE! THE MINIMUM HEIGHT OF THE CONCRETE WALL FROM THE FLOOR LEVEL SHOULD BE 1'-6". HOWEVER, THE CONCRETE WALL MAY BE EXTENDED TO THE HEIGHT OF THE WINDOW SILL IF DESIRED.

NOTE! THE MILK AND WASH ROOM MUST BE CEILED THROUGHOUT. IT IS PREFERABLE TO HAVE THE WALL CEILING PUT ON VERTICALLY TO FACILITATE CLEANING.

MINIMUM SIZES OF MILK ROOMS:
MILK OUTPUT: MIN. ROOM SIZE:
UNDER 50 GAL. 12' x 12' OR 144 SQ. FT.
50 - 100 GAL. 12' x 14' OR 168 SQ. FT.
100 - GAL. 12' x 16' OR 192 SQ. FT.

LSU
AgCenter
Research & Extension

SIX COW DAIRY BARN

ENGINEER J. D. CARTER	SCALE SHOWN
DRAWN BY J. D. CARTER	SHEET 1 OF 1
TRACED BY T. F. G.	DATE OCT 57 NO. 30-4

Disclaimer

This site makes available conceptual plans that can be helpful in developing building layouts and selecting equipment for various agricultural applications. These plans do not necessarily represent the most current technology or construction codes. They are not construction plans and do not replace the need for competent design assistance in developing safe, legal and well-functioning agricultural building system. The LSU Agriculture Center, the Mid-West Plan Service, the United States Department of Agriculture and none of the cooperating land-grant universities warranty these plans.